

SUNY CANTON CAMPUS SAFETY ISSUES/CONCERNS 11/19/19

NEW PROJECTS

(Update #2 as of 2/20/20)

	LOCATION	ISSUES/CONCERNS	ACTION
19-10-A	Traditional Dorm Lounge Area Lack of Outlets	Lack of outlets for students, students feel need to daisy chain extension cords to access power	O&M to take a look at installing more outlets 10/9/2019
19-11-B	Cooper-Coakleys Walkway	Lightpole light out at Cooper end near gate	Work Order No. 87862 submitted 11/20/2019 Requires new ballast and lamp (Requires additional troubleshooting) 2/20/20
19-11-D	Parking Lot#23	Lightpole light out near the practice field	Work Order No. 87864 submitted 11/20/2019 Requires new photo eye 2/20/20
19-11-E	Payson Hall, east, north and west exterior	Exterior lights at the north end of the building are out	Work Order No. 87865 submitted 11/20/2019 Temporarily hooked to lighting circuit, needs photo eye 2/20/20
19-11-G	Nevaldine North, north entrance	A light at exterior overhang is out	Work Order No. 87869 submitted 11/20/2019
19-11-H	Nevaldine South, north entrance outside Deb's Corner	A light at exterior overhang is out	Work Order No. 87868 submitted 11/20/2019
19-11-I	Bluelight #4 (MacArthur/Payson)	2 exterior canned lights are out	Temporarily hooked to lighting circuit, needs photo eye replaced 2/20/20
19-11-J	Parking Lot #1	2 lightpole lights are out	Work Order No. 87871 submitted 11/20/2019
19-11-K	Lot #13 near Davis Health Center	Lightpole light is out	Work Order No. 87872 submitted 11/20/2019

SUNY CANTON CAMPUS SAFETY ISSUES/CONCERNS 11/19/19

NEW PROJECTS

(Update #2 as of 2/20/20)

	LOCATION	ISSUES/CONCERNS	ACTION
19-11-N	Chaney Dining Hall exterior light near Golden Room	Exterior wall mounted light is not working	Work Order No.submitted 1/30/2020 Requires troubleshooting 2/20/2020
19-11-O	Walkway between MCC and Chaney Dining Hall	2 lightpole lights are out	Work Order No. 87874 submitted 11/20/2019 Requires additional troubleshooting in spring 2/20/2020
19-11-P	Walkway between Dana Hall and Heritage Hall	2 lightpole lights are out	Work Order No. 87875 submitted 11/20/2019 Requires additional troubleshooting 2/20/2020
19-11-Q	Payson Hall north walkway	Lightpole light is out	Work Order No. 87876 submitted 11/20/2019 Requires additional troubleshooting 2/20/2020

SUNY CANTON CAMPUS SAFETY WALK AROUND 11/19/19

COMPLETED PROJECTS SINCE LAST MEETING

(Update #2 as of 2/20/2020)

	LOCATION	ISSUES / CONCERNS	ACTION
19-11-A	Parking Lot#11 near Cooper main entrance	Lightpole light out	Work Order No. 87861 submitted 11/20/2019 Completed 2/20/20
19-11-C	Parking Lot#24	Lightpole light is dim at southwest corner of parking lot, the pole has a camera on it	Work Order No. 87863 submitted 11/20/2019 Completed 2/20/20
19-11-F	Walkway between Lot#7 and French Hall	Lightpole light is out	Work Order No. 87866 submitted 11/20/2019 Lamp replaced Complete 2/20/20
19-11-L	Miller Campus Center Plaza Entrance	2 interior entrance and 5 exterior lights are out	Work Order No. 87877 submitted 11/20/2019 Lamps repaced Completed 2/20/2020
19-11-M	Bluelight #15 (Smith Hall)	Bluelight phone will not ring into University Police	Repair Completed by IT 11/30/2020

SUNY CANTON CAMPUS SAFETY WALK AROUND 11/19/19

LONG TERM PROJECTS

(Update #2 as of 2/20/2020)

	LOCATION	ISSUES/CONCERNS	ACTION
10-01-A	Cooper walkway to Coakley's (2010)	In need of repair	Project subject to available Capital appropriation and Campus priority. This will be added to next Capital Plan request. Budget issue. 11/2/16 This will be added to Cooper Service Complex Parking Lot Rehab Capital Project No Change 9/27/2018 Reconstruct Cooper Service Parking Lot SUCF Project is in Design Phase, Schedule to begin Spring 2020 10/8/2019
12-03-A	Miller Drive walkway (2012)	Concerns over pedestrian safety with walkway crossing four parking lot exits, as well as the very close proximity to the drive - in the winter cars slide while turning onto Miller Drive, potentially endangering pedestrians	Constructed as per design documents for Kennedy Hall Housing project. Consideration should be given to design/construct a new elevated sidewalk and granite curb. Under review. Budget Issue 10/9/15 Installed new cross walk signs (12) at cross walks along Cornell Drive. No Change 9/27/2018 Reconstruct Miller Drive SUCF Project is Scheduled to begin Spring 2020 10/8/2019
15-01-A	Plaza	Paver stones on plaza, potential trip hazards	Various work orders to address paver conditions on the plaza have been submitted. Work has been completed to remove/replace deteriorated concrete sections at a cost of \$22,650. Approximately 2 dozen pavers were salvaged and are on pallets near the storage buildings at the CARC. Several thinner cut pavers also exist that could be utilized in non-traffic areas. Also on the same subject, it is noted at the end of the attached update "less sand usage on plaza and more salt". The greater use of salt has severely deteriorated pavers as well as other concrete surfaces. It is also recommended that hard rubber cutting edges be used on snow removal equipment in lieu of steel cutting edges which has also caused premature failure of the pavers. M&O Issue. Approximately 16 pallets of 1 1/2" pavers and 16 pallets of 2 1/2" pavers were salvaged from Payson Hall East project that could be used to replace existing pavers in poor condition. No Change 10/10/17. Failed pavers replaced during summer of 2018. Paver replacement will be ongoing 9/27/2018 Combined into Site Project 2/22/2019 Site Improvements French Hall & Roselle Plaza SUCF Project is in Design Phase, Scheduled to begin Spring 2020 10/8/2019
15-10-A	Campus wide	Signage across campus	Working on additional way finding signage on Cornell Dr. and Campus Map update. 11/2/16 New campus map has been ordered. New campus maps installed. Replacement of signage along Cornell Drive planned Spring 2018. No Change 9/27/2018 Combined into Site Project 2/22/2019

16-11-A	French Hall East Exterior	Rear Plaza concrete walkway, granite walls, and inadequate lighting issues	Project subject to available Capital appropriation and Campus priority. This will be included in future project requests 2/13/2017 No Change 10/10/17. Items 16-11-C & 18-4-D were added to this item, to be taken care of as part of a French Hall Exterior Project . Walkway temporarily patched by Physical Plant in Summer 2018 9/27/2018 Combined into Site Project 2/22/2019 Site Improvements French Hall & Roselle Plaza SUCF Project is in Design Phase, Scheduled to begin Spring 2020 10/8/2019
16-11-C	Cook Hall/French Hall	Walkway northeast of French Hall and Southwest of Cook Hall has inadequate lighting	Facilities is going to check if site drawings indicate if a pole is supposed to be in that area. Under review. No Change 2/10/2017 Item to be repaired as part of upcoming French Hall Exterior Renovation Project 9/5/2018 Combined into Site Project 2/22/2019 Site Improvements French Hall & Roselle Plaza SUCF Project is in Design Phase, Scheduled to begin Spring 2020 10/8/2019
16-11-B	Heritage Hall	Trash disposal area in the basement is isolated and may be a good place to establish a security camera and/or limited card access.	Work to be completed via Construction Change Directive to current contract for Rehab Mohawk Hall East project. Work to be complete August 2017. Work included in Rushton Hall East Wing Rehab project. No Change 9/27/2018 Cameras were added to Rushton Hall East as part of the rehab project 11/29/2018 Purchase Order for S&L is on system, nine works to be installed in Heritage & Mohawk 2/22/2019 Cameras have been installed Complete 10/7/2019
18-4-C	Miller Drive	Potholes in road between Newell and Nevaldine	Work Order 81645 submitted 9/5/2018 Temporary Patch Completed. This item will be included in future project requests 9/27/2018 Project is in Design Phase 10/7/2019 Reconstruct Cooper Service Parking Lot SUCF Project is in Design Phase, Schedule to begin Spring 2020 10/8/2019
19-04-N	Chaney Dining Hall (Burma Drive)	Lightpole is leaning and asphalt condition	Punch list work is ongoing related to the Chaney Dining Hall Rehab. Also, we have budgeted, and plan to reconstruct Burma Drive including updating the lighting as a MCM project.4/18/2019 Facilities is working with SUCF and General Contractor to complete remaining exterior work 10/8/2019

Current & Upcoming Projects
231018 - Rehab Dana Hall Phase II Interior Renovations
231033 - Site Improvements French Hall & Roselle Plaza
231036 - Reconstruct Miller Drive (Scheduled to begin May/June 2020 pending budget)
231037 - Reconstruct Parking Lot No. 1 (Scheduled to begin May/June 2020 pending budget)
231038 - Reconstruct Cooper Service Complex Parking Lot (Scheduled to begin May/June 2020 pending budget)