SUNY CANTON CAMPUS SAFETY ISSUES/CONCERNS 11/7/2024

LIST OF NEW PROJECTS

(Update #2 as of 3/3/25)

| | (Opuate #2 as of | 5/5/25/ |
|---|--|--|
| LOCATION | ISSUES/CONCERNS | ACTION |
| | Pavers are broken and concrete cracked | WO 109209 Waiting on warmer weather |
| Rushton Hall main entrance near gazebo | | WO 109213 Waiting on warmer weather |
| | Light is flickering | WO 109218 Waiting on parts |
| Miller Campus Center cul-de- sac | Light poles lights are out | Lights are out due to the on-going construction project of the stairs between Payson Hall and Heritage and Rushton Halls |
| Residence Halls | Gazebos Safety Concerns | Need to develop a plan for replacement |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | MacArthur Hall Entrance Exterior Rushton Hall main entrance near | LOCATION MacArthur Hall Entrance Exterior Pavers are broken and concrete cracked Rushton Hall main entrance near gazebo Light is flickering Payson Hall north entrance exterior soffit recessed light Miller Campus Center cul-desac Light poles lights are out |

SUNY CANTON CAMPUS SAFETY ISSUES/CONCERNS 11/7/2024 LIST OF COMPLETED PROJECTS SINCE LAST MEETING ON NOVEMBER 7TH

(Update #1 as of 11/26/24)

| | | | 1 as 01 11/20/24) |
|---------|---|---------------------------|--|
| ITEM | LOCATION | ISSUES/CONCERNS | ACTION |
| 24-11-B | French Hall west side soffit | Recessed light is out | WO 109210 Replaced; WO Closed 12/30 |
| 24-11-C | Cornell Drive near lot #6 | Pole light is out | WO 109211 Received 11/26, WO Closed 3/12 |
| 24-11-D | CARC main entrance near statue | Wall light is out | WO 109212 Replaced ballast; WO Closed 12/3 |
| 24-11-F | Lot #3 | Car is up on jacks | Jacks were removed per University Police, Complete |
| 24-11-G | CARC ice rink exterior entrance above door | Wall light is out | WO 109214 Replaced lamp; WO Closed 12/3 |
| | Cooper Service Complex main entrance soffit recessed light | Light is out | WO 109215 Completed; WO Closed 12/11 |
| 24-11-I | Cooper Service Complex loading dock soffit recessed light | Light is flickering | WO 109215 Completed; WO Complete 12/11 |
| | Nevaldine Southeast exterior soffit | Light is out | WO 109216 Replaced lamp; WO Closed 12/10 |
| 24-11-K | Kennedy Hall parking Lot #24 | Blue light is out | WO 109217 Changed Blue Light; WO Complete 12/11 |
| 24-11-0 | CARC entrance near Lot #4 | 2 pedestal lights are out | WO 109220 Fixed; WO Complete 12/5 |
| | | | |
| | | | |

| LIST OF LONG-TERM PROJECTS 11/7/2024 | | | | | |
|--------------------------------------|----------------------------|--|---|--|--|
| | (Update #1 as of 11/26/24) | | | | |
| ITEM | LOCATION | ISSUES/CONCERNS | ACTION | | |
| 15-01-A | Plaza | Paver stones on plaza, potential trip hazards, | Roselle Plaza Renovation (Phase III) is in design phase, construction anticipated to begin in 2025. | | |