



Office of the Vice President for Administration

State University of New York • 34 Cornell Dr. • Canton, NY 13617-1096 • www.canton.edu

Shawn K. Miller
VP for Administration
Record Access Officer
Office 315-379-3820
Fax 315-386-7606
millers@canton.edu

April 11, 2018

Deputy Chief Brian McCrae
Division of Homeland Security and Emergency Services
NYS Office of Fire Prevention and Control
State Office Campus, Building 7A-Floor 2
1220 Washington Avenue
Albany, NY 12226

Deputy Chief McCrae:

SUNY Canton is requesting a time extension for four violations at this time. The issues were identified during our annual campus fire inspection (part II) conducted by Fire Protection Specialist Ken McGowan and SUNY Canton Representatives on April 5, 2018.

The justification for this extension and the extension request date is listed on the attached spreadsheet.

If you would like to discuss this time extension request, I can be reached at (315) 379-3820.

Thank you for your time and consideration on this matter.

Regards,

A handwritten signature in blue ink that reads "Shawn K. Miller".

Shawn K. Miller
VP for Administration
Chief Financial Officer
SUNY Canton College of Technology

Attachments (1)

**SUNY CANTON COMPLIANCE PLAN
for 2018 OFPC FIRE SAFETY INSPECTIONS**

DATE: 4/10/18

State Fire ID:	Building	Violation #	Compliance Description	Extension Date Requested
1-01-00-0020-005	Miller Campus Center	60	SUNY Canton will install heat detector near ceiling in room. Ceiling is approximately 24 feet high with obstructions that need to be cleared with a ladder or man lift.	6/30/2018
1-01-00-0020-008	Southworth Library	20	SUNY Canton will install sprinkler escutcheons after adjusting sprinkler piping in new second floor ceiling.	6/30/2018
1-01-00-0020-014	Smith Hall	41	SUNY Canton will fire-stop all ceiling penetrations in basement area.	6/30/2018
1-01-00-0020-016	Wicks Hall	27	SUNY Canton will re-hang the glass fire door.	6/30/2018