



State of New York
Office of Fire Prevention and Control

1220 Washington Avenue, Bldg 7A
Albany, NY 12226
Phone#: (518) 474-6746
Fax#: (518) 474-3240

REPORT OF RE-INSPECTION AND ORDER TO COMPLY

Facility: SUNY Canton College of Technology

The Office of Fire Prevention and Control has identified that violations of the Uniform Fire Prevention and Building Code, previously identified in a Report of Inspection, continue to exist in a building or buildings under the jurisdiction of your college or university.

These violations pose a potential for physical injury or death to the occupants of the building due to fire. Failure to remedy the violations by the date specified will result in fines ranging from \$50 to \$500 per violation, per day; the violation(s) continues to exist beyond the established abatement date. Furthermore, closure of the building may be directed if conditions constitute an imminent threat to public health or safety, until subsequent inspection reveals that all violations have been remedied.

Any specific questions relating to this inspection should be directed to the New York State Office of Fire Prevention and Control - Fire and Life Safety Branch at the location indicated below.

District Supervisor:

McCrae, Brian
Deputy Chief

Inspector : Charland, Victoria



1220 Washington Ave.
State Office Campus Building 7A, Floor 2
Albany, NY 12226
518-474-6746 518-474-3240
(fax)fire@dhses.ny.gov



State of New York
Office of Fire Prevention and Control

1220 Washington Avenue, Bldg 7A
Albany, NY 12226
Phone#: (518) 474-6746
Fax#: (518) 474-3240

REPORT OF RE-INSPECTION NOTICE OF VIOLATION

Agency: State University of New York
Region: None
Facility: SUNY Canton College of Technology

System ID#: 717
Building No.: 015
Escort:

Building: Macarthur Hall
34 Cornell Dr, 015
Canton, NY 13617

Orig. Inspector: Charland, Victoria
Orig. Insp. Date:
Re-inspected by: Charland, Victoria
Re-inspection date: 04/11/2024
Next Re-insp. due: 05/11/2024
Page 1

----- Violations -----

46 Violation: Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency where the building area served by the means of egress is occupied. An exit

Hazard Cls.: Minimal

Code Refer.: 20F-1031.2

Abate By: 04/04/2024

Location: Roos Court

Description: Refrigerator blocking egress from one side of the food preparation area.

ADDITIONAL EXPLANATION

Violation#: 44 Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises

Part II-General Safety Provisions

CHAPTER 3 GENERAL REQUIREMENTS

SECTION 304 COMBUSTIBLE WASTE MATERIAL

304.1 Waste accumulation prohibited. Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.

304.1.1 Waste material. Accumulations of wastepaper, wood, hay, straw, weeds, litter or combustible or flammable waste or rubbish of any type shall not be permitted to remain on a roof or in any court, yard, vacant lot, alley, parking lot, open space, or beneath a grandstand, bleacher, pier, wharf, manufactured home, recreational vehicle or other similar structure.

304.1.2 Vegetation. Weeds, grass, vines or other growth that is capable of being ignited and endangering property, shall be cut down and removed by the owner or occupant of the premises.

304.1.3 Space underneath seats. Spaces underneath grandstand and bleacher seats shall be kept free from combustible and flammable materials. Except where enclosed in not less than 1-hour fire-resistance-rated construction in accordance with the Building Code of New York State.

Violation#: 45 Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible building official. Electrical wiring, devices, appliances and other equipment that is modifi

Part III-Building and Equipment Design Features

CHAPTER 6 BUILDING SERVICES AND SYSTEMS

SECTION 604 ELECTRICAL EQUIPMENT, WIRING AND HAZARDS

604.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible building official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

Violation#: 46 Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency where the building area served by the means of egress is occupied. An exit

Part III—Building and Equipment Design Features

CHAPTER 10 MEANS OF EGRESS

SECTION 1031 MAINTENANCE OF THE MEANS OF EGRESS

1031.2 Reliability. Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency where the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

1031.2.1 Security devices and egress locks. Security devices affecting means of egress shall be subject to approval of the fire code official. Security devices and locking arrangements in the means of egress that restrict, control, or delay egress shall be installed and maintained as required by this chapter.

1031.2.2 Locking arrangements in educational occupancies. In Group E occupancies, Group B educational occupancies and Group I-4 occupancies, egress doors from classrooms, offices and other occupied rooms shall be permitted to be provided with locking arrangements designed to keep intruders from entering the room where all of the following conditions are met:

- (1.) The door shall be capable of being unlocked from outside the room with a key or other approved means.
 - (2.) The door shall be openable from within the room in accordance with Section 1010.1.9.
 - (3.) Modifications shall not be made to existing listed panic hardware, fire door hardware or door closers.
 - (4.) Modifications to fire door assemblies shall be in accordance with NFPA 80.
-

ADMINISTRATIVE RIGHT OF APPEAL

GENERAL

Requests for clarification and questions related to this inspection report should be directed first to the inspector identified on the report. Follow up or further inquiry may be made to the district supervisor of the Office of Fire Prevention and Control, Fire and Life Safety Branch responsible for the region in which the building is located.

To formally dispute a violation, a request for review must be presented in writing, with clear explanation of the circumstances to:

Chief of the Fire and Life Safety Branch
Office of Fire Prevention and Control
1220 Washington Avenue, Bldg 7A
Albany, NY 12226
(518)-474-6746

If there is the desire to challenge that determination a formal appeal may be made to the Deputy State Fire Administrator for Enforcement at the above address. Such appeal must be presented in writing and clearly detail justification for the dispute.

LEGAL VARIANCE

To pursue relief from strict application of the requirements of the New York State Uniform Fire Prevention and Building Code (Uniform Code), a “variance” may be pursued. The procedures for variances and appeals regarding the Uniform Code are established in [19 NYCRR Part 1205](#). Requests for a variance generally require a hearing before a [Board of Review](#). Some requests for a variance can be resolved through an administrative process when NYS Department of State staff determines it is appropriate. For additional information, or to initiate a variance or appeal process, contact should be made with the appropriate Department of State [regional](#) office. An application for a variance or appeal of a local determination regarding applicable provisions of the New York State Uniform Fire Prevention and Building Code may be found at:

http://www.dos.ny.gov/dcea/pdf/varianceapp_311.pdf

COMPLIANCE PLANS

With justification, a time extension to abate a specific violation may be granted. Such extensions are determined “Compliance Plans” because they are only considered if the request demonstrates a detailed, legitimate plan that reasonably assures compliance by the date requested. Compliance plans may be submitted as a written request to the regional Fire and Life Safety Branch Deputy Chief at the address provided on this notice. To be considered, the request must be in writing and must set forth work already accomplished, the work remaining, the reason why an extension of time is necessary, and the date by which all work will be completed. All possible supporting and justifying documentation should accompany the request. Time extensions are not automatic or guaranteed. They are granted solely on the merit of each compliance plan. The compliance plan must be completed and signed by a member of the requesting agency’s management team that is authorized to commit project funding, provide timelines, and commit the agency to the legal specifications of the request.

Take notice that an application for an extension constitutes a legal obligation to correct the violation by the date granted and that failure to meet the conditions of said compliance plan will result in the assessment of penalties accrued during the extension period.